

Lab Name \_\_\_\_\_

• Is the water clear?

Office of Laboratory Safety 2300 | Street, NW Ross Hall, Suite B-05 Washington, DC 20037 t. 202-994-8258 | labsafety@gwu.edu

## **Eyewash Station Weekly Inspection Checklist**

Please flush eyewash stations weekly for at least 30 seconds and check for the following:

Lab Manager \_\_\_\_\_

o If yes, contact facilities to repair the unit as soon as possible			